



CB TEST CERTIFICATE

Ref. Certificate No.

NL-34056

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	RCBO		
Applicant:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Manufacturer:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Factory:	Zhejiang Chint Electrics Co., Ltd	No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang	China
Rating and principal characteristics:	2P , Ue = 220 / 230 / 240 Vac, 50 / 60 Hz In = 6, 10, 13, 16, 20, 25, 32 A B and C - type, I Δ n = 0,03 A for all In Type A, without time-delay, Ics = Icn = 6000 A, I Δ m = 3000 A Safety distance= 50 mm, Temperature limit: - 25 °C ... + 40 °C (-25°C was tested according to EN61009-1) Reference ambient temperature : 30 °C		
Trade mark (if any):	CHINT		
Model/Type reference:	NB310L		
Additional information:	Energy limiting class 3 according to EN 61009-1:2012. This certificate is based on and replaces CB certificate no. NL-26939 issued on 2013-06-05.		
Sample of product tested to be in conformity with IEC:	61009-1(ed.3);am1 61009-2-1(ed.1)		
Test Report Ref. No:	3307147.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands



Signed by: F.S.Strikwerda

Date of issue: 2015-01-23